



Date: 06 Jan 2026

CORRIGENDUM

In partial modification to the Accreditation Certificate issued by Indian Road Congress vide letter No.IRC:24(7)/2018(ACC-255) dated 19.08.2025 to M/s Penetron India Pvt. Limited for their product "Penetron Admix- Crystalline Waterproofing Admixture", Para No.5 of the certificate may be read as following:

FOR	READ
Para No. 5 Based on submitted documents, Accreditation Committee recommended Penetron Admix can be used with any commonly used mix design (no limitations towards w/c ratio or cement content), low dosages rates (0.8% by weight of total cementitious content).	Para No.5 Based on submitted documents, Accreditation Committee recommended Penetron Admix can be used for concrete of M-40(and above grade), low dosages rates (0.8% by weight of total cementitious content).

2. All other paras of the Certificate No. No.IRC:24(7)/2018(ACC-255) dated- 19.08.2025 shall remain unchanged.

This issues with the approval of competent Authority.


06-01-2026

(Atul Pundir)
Deputy Director(Tech.)-II

Please Note : All correspondence should be addressed to the Secretary General by designation only

मुख्यालय : कामा कोटि मार्ग, सेक्टर-6, रामा कृष्णा पुरम, नई दिल्ली-110 022 (भारत)
Headquarter : Kama Koti Marg, Sector-6, R.K. Puram, New Delhi-110 022 (INDIA)
दूरभाष : +91 11 26105160, 26185273, 26171548, 26185315